

$\rho=1050\Omega\text{-cm}$: within 4.0%

$\rho=1400\Omega\text{-cm}$: within 3.4%

$\rho=1950\Omega\text{-cm}$: within 3.3%

and when assuming E_0 equal to E_0 in eq ①

$\rho=1050\Omega\text{-cm}$: within 10.5%

$\rho=1400\Omega\text{-cm}$: within 7.7%

$\rho=1950\Omega\text{-cm}$: within 3.3%

(4) In the case of extending a small experimental pipe size to semi-practical one, the voltage of electric power source required for corrosion prevention is corrected as follow.

$$V_0 = I_0(-0.5317973 \log I_0 + 1.7299687) \{0.0723 + 0.0144 \log(50h)\} \times \rho \times 10^{-3} + 1.85 \text{ (V)} \quad \textcircled{6}$$

$$I_0 = i_0 \pi DL \times 10^{-4} \text{ (mA)} \quad \textcircled{7}$$

水酸化나트륨과 鹽酸 水溶液에서의 니켈과 Inconel 600의 280°C에서의 腐蝕行動

李仁鍾·石兌元

韓國 原子力 研究所

The Corrosion Behavior of Nickel and Inconel 600 in Sodium Hydroxide and Hydrochloric Acid Solution at 280°C

Ihn Chong Lee, Tae Won Suk

Korea Atomic Energy Research Institute

要 約

니켈과 Inconel 600의 腐蝕行動이 용액의 pH 3~13 범위에서 무게變化測定法에 의하여 研究되었다. 試片은 210 시간동안 280°C의 autoclave에서 靜的인 腐蝕水溶液에 露出되었다. 이 溶液의 pH는 염산과 수산화나트륨으로 調節되었으며 溶存酸素의 濃度는 순수한 질소가스를 이용하여 10ppb가 되도록 하였다. 實驗된 pH 범위에서 Inconel 600의 무게 減少는 니켈의 무게 減少보다 적었다. pH 9.5에서 니켈과 Inconel 600의 最少 무게減少現象을 보여 주었으며 무게 減少量은 각각 1.5mg/dm², 0.9mg/dm²이었다. 金屬顯微鏡으로 觀察한 바에 의하면 니켈의 表面은 均일하게 腐蝕된 반면 Inconel 600의 表面은 원래의 微細構造와 큰 差異가 없었다.

Abstract

The corrosion behavior of nickel and Inconel 600 has been investigated by the weight change measurement method at pH ranges 3~13 of the solution. The specimens were exposed to aqueous solutions in a static autoclave at 280°C for 210 hours. The pH of the solutions was adjusted by hydrochloric acid and sodium hydroxide and the dissolved oxygen concentration was fixed as 10 ppb by using pure nitrogen gas. Weight loss of Inconel 600 was much less than that of nickel over the tested pH ranges. At pH 9.5 nickel and Inconel 600 showed the minimum weight loss phenomenon and the values of weight loss were 1.5mg/dm² and 0.9mg/dm², respectively. Microscopic examination showed that nickel surface was attacked uniformly, whereas Inconel 600 surface was not greatly different from the original microstructure.